

**The Following information regarding this incident has been reported:**

**Reporting Date:** 10/24/2019 11:30:45 AM

**Incident Date:** 10/23/2019 @ 9:20 p.m.

**Reported By:** Meredith Allen, Sr. Director

**Utility Name:** PG&E

**Phone Number:** (415)828-5765

**Email Address:** [MEAe@pge.com](mailto:MEAe@pge.com)

**Incident Location:** Near Kincade Rd and Burned Mountain Rd Cloverdale, Sonoma

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? No (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? Yes

**Cause of Incident:** Unknown (Other Cause: )

**Agencies on Scene:**

**Facilities Affected:**

- Utilities Facilities: Geysers #9 - Lakeville
- Voltage (KV): 230
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:

- Contact:

- Phone: (\_\_\_\_)\_\_\_\_ - \_\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.

- Service Restored: @ 00:00 a.m.

**Summary:** At approximately 2120 hours on October 23, 2019, PG&E became aware of a Transmission level outage on the Geysers #9 Lakeville 230kV line when the line relayed and did not reclose. At approximately 0730 hours on October 24, 2019, a responding PG&E Troublemán patrolling the Geysers #9 Lakeville 230 kV line observed that CAL FIRE had taped off the area around the base of transmission tower 001/006. On site CAL FIRE personnel brought to the Troublemán's attention what appeared to be a broken jumper on the same tower. PG&E is reporting this incident under the Media Criterion. This information is preliminary.