



County of Durham

OFFICE OF THE FIRE MARSHAL

Phone (919) 560-0660 Fax (919) 560-0670



FD CITY

FIRE INSPECTION REPORT

TIME 2:30

DATE 20 SEPT 2007 INSPECTOR Michael Webb

OCCUPANT Forest View Elementary School PHONE 560-3932

LOCATION 3007 Mt. Siani Road Durham 27705

OWNER/AGENT Lisa Napp PHONE _____

TYPE OF INSPECTION FIRE X HAZMAT _____

ANNUAL Fall 07 REINSPECTION 1ST _____ 2ND _____ TIME LIMIT FOR CORR. 30 Day

PROPERTY USE: Assembly Business Educational Hazardous Factory-Industrial
 Institutional Mercantile Residential Storage Other _____

SPRINKLER SYSTEM _____ STANDPIPE SYSTEM _____ HALON SYSTEM _____ HOOD SYSTEM June 7 EMERGENCY LIGHTS * OTHER _____

FIRE/SMOKE ALARM SYSTEM ✓ FIRE EXTINGUISHERS AD 207 HYDRANT LOCATION _____ WATER SUPPLY _____

CHEMICAL STORAGE RM _____ CONTAINMENT AGT'S _____ FLAMMABLE STORAGE _____ CYLINDER STORAGE _____

Conditions, surroundings and arrangements to be in accordance with the NC State Building Code; NC Fire Code; Durham County Fire Prevention & Protection Code.

- ✓ - Smoke DETECTOR NEEDS BATTERY T-4
- MISSING FIRE EVALUATION PLAN RM B-5
- AIR FILTERS NEED TO BE CLEANED THROUGHOUT SCHOOL
- ✓ - Emergency lights BROKEN NEAR AD-6, BETWEEN B-3 + B-5, A5 + A7
NEXT TO B-1, KITCHEN, ACROSS FROM A-WORKROOM
- ✓ - EXIT LIGHT OUT NEAR AD-6, MULTI-PURPOSE ROOM, T-6
- ✓ - Emergency EXIT window BLOCKED B-7, B-1

Sandy Celestine
Signature of Occupant

All owners or tenants of buildings in Durham County, which are required to be inspected by the Durham County Fire Marshal's Office are subject to the following fire prevention inspection fee schedule:		
Periodic Inspection		None
First Inspection pursuant to permit application		None
First reinspection for non-compliance, if code requirements are met		None
First reinspection for non-compliance, if code requirements are <u>not</u> met		\$100.00
Second and subsequent reinspections for non-compliance		\$200.00

Initials:
LS