



FIRE INSPECTION REPORT - NOTICE OF FIRE CODE VIOLATION

Date of Inspection: Tue Apr 8, 2008 Time: 10:30
Inspection Type: Inspection - Public School/Fire &

BUSINESS/OPERATION
Bugg Elementary School
825 COOPER RD
Raleigh, NC 27610

Date of Next Reinspection: _____

THE FOLLOWING ITEMS ARE IN VIOLATION OF THE N.C. STATE FIRE PREVENTION CODE. YOU ARE REQUIRED TO CORRECT ALL ITEMS NOTED BELOW:

Code	Correction to be Made
1025.1 General.	In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group E classrooms ****1) EMERGENCY WINDOW OBSTRUCTED: 208
1025.1 General.	Violation carried over from inspection on 10/11/2007 Violation carried over from inspection on 04/18/2007 In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group E classrooms ****1) STORAGE ROOM USED AS A CLASSROOM : ESL ROOM -MEDIA CAN NOT USE FOR A CLASSROOM: NO SECONDARY MEANS OF EGRESS ROOM MEASURES 288 SQ.FT. 1 DOOR NO WINDOWS //////////////////////////////////// AS OF 04/08/08 THE ABOVE VIOLATION-NOT CORRECTED
1027.2 Reliability.	Required exit accesses, exits or exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency when the areas served by such exits are occupied. Security devices affecting means of egress shall be subject to approval of the fire code official. ****1) MAINTAIN CLEAR ACCESS TO EXITWAY : DESK: BACK DOOR : 210
315.2.1 Ceiling clearance.	Storage shall be maintained 2 feet or more below the ceiling in nonsprinklered areas of buildings or a minimum of 18 inches below sprinkler head deflectors in sprinklered areas of buildings. ****1) MAINTAIN CLEARANCE FROM CEILING FOR STORED ITEMS: 101-STORAGE
315.2.1 Ceiling clearance.	Violation carried over from inspection on 10/11/2007 Storage shall be maintained 2 feet or more below the ceiling in nonsprinklered areas of buildings or a minimum of 18 inches below sprinkler head deflectors in sprinklered areas of buildings. MAINTAIN CLEARANCE FROM CEILING FOR STORED ITEMS: ****1) 101-STORAGE //////////////////////////////////// AS OF 04/08/08 THE ABOVE VIOLATION-NOT CORRECTED