



**FIRE INSPECTION REPORT - NOTICE OF FIRE CODE VIOLATION**

Date of Inspection: Wed Apr 9, 2008

Time: 10:30

Inspection Type: Inspection - Public School/Fire &

**BUSINESS/OPERATION**

Cary Elementary School  
400 KILDAIRE FARM RD

Cary, NC 27511

Date of Next Reinspection: \_\_\_\_\_

THE FOLLOWING ITEMS ARE IN VIOLATION OF THE N.C. STATE FIRE PREVENTION CODE. YOU ARE REQUIRED TO CORRECT ALL ITEMS NOTED BELOW:

**Code Correction to be Made**

**1011.5.3 Power source.**

Exit signs shall be illuminated at all times.

\*\*\*\*1) EXIT SIGN : NOT WORKING : GYM EXIT :

**1025.1 General.**

In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group E classrooms

EMERGENCY WINDOW OBSTRUCTED:

\*\*\*\*1) 2311

\*\*\*\*2) 2315

\*\*\*\*3) 2316

**1025.1 General.**

Violation carried over from inspection on 10/01/2007

In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group E classrooms

EMERGENCY WINDOW OBSTRUCTED:

\*\*\*\*1) 2311

\*\*\*\*2) 2315

////////////////////////////////////  
AS OF 04/08/08 THE ABOVE VIOLATION-NOT CORRECTED

**605.1 Abatement of electrical hazards.**

Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the code official responsible for enforcement of the ICC Electrical Code. Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used.

\*\*\*\*1) CORD IN DOORWAY TO NEXT ROOM : 214

NEED PERMANENT RECEPTACLE FOR PRINTER OR MOVE EQUIPMENT

**605.3 Working space and clearance.**

A working space of not less than 30 inches in width, 36 inches in depth and 78 inches in height shall be provided in front of electrical service equipment. Where the electrical service equipment is wider than 30 inches, the working space shall not be less than the width of the equipment. No storage of any materials shall be located within the designated working space.

\*\*\*\*1) MAINTAIN CLEARANCE IN FRONT OF ELECTRICAL PANEL : 505