



FIRE INSPECTION REPORT - NOTICE OF FIRE CODE VIOLATION

Date of Inspection: Wed Feb 13, 2008

Time: 12:30

Inspection Type: Inspection - Public School/Fire &

BUSINESS/OPERATION

Forest Pines Elem. School

11455 FOREST PINES DR

Raleigh, NC 27601

Date of Next Reinspection: _____

THE FOLLOWING ITEMS ARE IN VIOLATION OF THE N.C. STATE FIRE PREVENTION CODE. YOU ARE REQUIRED TO CORRECT ALL ITEMS NOTED BELOW:

907.10.1.1 Public and common areas.

Visible alarm notification appliances shall be provided in public areas and common areas.

Fire alarm strobe needs to be added to room 1101-G, room now being used as a classroom for ALP

907.20.1 Maintenance required.

Whenever or wherever any device, equipment, system, condition, arrangement, level of protection or any other feature is required for compliance with the provisions of this code, such device, equipment, system, condition, arrangement, level of protection or other feature shall thereafter be continuously maintained in accordance with applicable NFPA requirements or as directed by the fire code official.

The fire alarm was found to be in the TROUBLE MODE. (Card 3, SDACT, Card Missing) Have addressed.

9999.1 Violation not classified

The steps leading from the Multi-Purpose Room Stage into the storage room along the left side of the stage are made of wood. Wood steps are not consistent with the type of building construction. Reference NC Building Code Chapter 6

NON-COMPLIANCE FEES WILL BE CHARGED UNLESS ALL VIOLATIONS ARE CORRECTED BY THE MUTUALLY AGREED UPON REINSPECTION DATE

WHOEVER FAILS TO COMPLY WITH ANY ORDER ISSUED BY THE FIRE MARSHAL OR HIS DEPUTY MAY BE CHARGED WITH A MISDEMEANOR AS PROVIDED BY G.S.153A-123(b) AND G.S.14.4. EACH DAY'S CONTINUING VIOLATION OF THE CODE IS A SEPARATE AND DISTINCT OFFENSE AS PROVIDED FOR IN G.S. 153A-123(g). CIVIL PENALTIES MAY ALSO BE ASSESSED. NON-COMPLIANCE CONSTITUTES REINSPECTION FEES. I AGREE TO CORRECT THE ABOVE VIOLATIONS BY THE MUTUALLY AGREED UPON REINSPECTION DATE. ALL FIRE INSPECTION REPORTS ARE PUBLIC RECORD AND ARE AVAILABLE UPON WRITTEN REQUEST.

Gupton, H. Lee
Deputy Fire Marshal

919-856-5625

X _____
Occupant/Owner