



FIRE INSPECTION REPORT - NOTICE OF FIRE CODE VIOLATION

Date of Inspection: Thu Mar 27, 2008 Time: 10:30
Inspection Type: Inspection - Public School/Fire &

BUSINESS/OPERATION
Holly Ridge Elementary
900 Holly Springs RD
Holly Springs, NC 27540

Date of Next Reinspection: _____

THE FOLLOWING ITEMS ARE IN VIOLATION OF THE N.C. STATE FIRE PREVENTION CODE. YOU ARE REQUIRED TO CORRECT ALL ITEMS NOTED BELOW:

Code	Correction to be Made
1025.1 General.	In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group E classrooms EMERGENCY WINDOW OBSTRUCTED: ****1) 1108-COVERED ****2) 2202 ****3) 2205 ****4) 2311
1025.1 General.	In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group E classrooms ****1) CAN NOT USE ROOM FOR CLASSROOM: 1313
1025.1 General.	Violation carried over from inspection on 09/26/2007 In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group E classrooms EMERGENCY WINDOW OBSTRUCTED: ITEMS IN FRONT OF WINDOW: ****1) 2202 //////////////////////////////////// AS OF 03/27/08 THE ABOVE VIOLATION-NOT CORRECTED
1025.1 General.	Violation carried over from inspection on 09/26/2007 Violation carried over from inspection on 02/14/2007 In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group E classrooms EMERGENCY WINDOWS BLOCKED: ITEMS IN FRONT OF WINDOW: ****1) 2202 //////////////////////////////////// AS OF 03/27/08 THE ABOVE VIOLATION-NOT CORRECTED