State of North Carolina County of Wake Department of Public Safety



331 South McDowell Street Raleigh, North Carolina 27601 Phone 919-856-6340 Fax 919-856-6236 www.WakeGov.com

FIRE INSPECTION REPORT - NOTICE OF FIRE CODE VIOLATION

Date of Inspection: Thu Apr 10, 2008 Time: 10:45

Inspection Type: Inspection - Public School/Fire &

BUSINESS/OPERATION

Lincoln Heights Elementary School 307 BRIDGE ST

Fuguay-Varina, NC 27526

Date of Next Reinspection:

THE FOLLOWING ITEMS ARE IN VIOLATION OF THE N.C. STATE FIRE PREVENTION CODE. YOU ARE REQUIRED TO CORRECT ALL ITEMS NOTED BELOW:

Code Correction to be Made 1025.1 General. In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group E classrooms EMERGENCY WINDOW OBSTRUCTED:

****1) 200

****2) 201

****3) 205

1025.1 General.

Violation carried over from inspection on 10/08/2007

In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group E classrooms

EMERGENCY WINDOW OBSTRUCTED:

****1) 201

****2) 205

AS OF 04/10/08 THE ABOVE VIOLATION-NOT CORRECTED

1025.1 General

Violation carried over from inspection on 10/08/2007

In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group E classrooms

****1) CAN NOT USE ROOM FOR CLASSROOM: 161

NO SECONDARY MEANS OF EGRESS

AS OF 04/10/08 THE ABOVE VIOLATION-NOT CORRECTED

1027.2 Reliability.

Required exit accesses, exits or exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency when the areas served by such exits are occupied. Security devices affecting means of egress shall be subject to approval of the fire code official.

MAINTAIN CLEAR ACCESS TO EXITS:

****1) SIDE DOOR : 124

****2) BACK DOOR : T-210

1